

MECHANICAL VENTILATION INSTRUCTIONS

With this wireless control switch, the ventilation unit can be set to different ventilation modes (capacities):

- **Auto mode (automatic mode):** regulation based on available sensors (CO₂ and/or humidity). The capacity is automatically adjusted between the lowest and highest level.
- **Level 1 (low):** when one person is present or when no one is present.
- **Level 3 (high):** during cooking, showering, or bathing, or when multiple people are present.
- **Timer:** for switching the unit to high mode for a set period.

When using sensors, the duration that the ventilation unit can remain in a mode other than automatic is limited to 24 hours for Dutch units and 12 hours for Belgian units. After this period, the unit switches back to automatic mode.

Timer

- Press once: 10 minutes high mode
- Press twice: 20 minutes high mode
- Press three times: 30 minutes high mode

When used **without sensors**, after the timer ends the unit returns to the last selected setting before the timer was activated, unless this was high mode. In that case, the unit switches to a lower setting.

When used **with sensors**, the unit returns to automatic mode.

Interrupting the timer: Press another setting.